

TEST REPORT

 KERI



KERI



한국전기연구원
KOREA ELECTROTECHNOLOGY
RESEARCH INSTITUTE

TEST REPORT

2009TS02275 1/3

CLASSIFICATION Performance Test(III)
APPARATUS Surge Protective Device
DESIGNATION LP-34-38-40M
RATINGS AC 400Y/230 V
APPLIED STANDARD Applicant's specifications
RECEIPT No. TRD09S02539 (October 14, 2009)
APPLICANT Ground Co., Ltd.
#209, Suntech City 2 307-2 Sangdaewon-dong Joongwon-gu
Seongnam-si Gyeonggi-do Korea
MANUFACTURER Ground Co., Ltd.
#209, Suntech City 2, 307-2 Sangdaewon-dong Joongwon-gu
Seongnam-si Gyeonggi-do Korea
DATE OF TESTS October 27, 2009
DATE OF ISSUE November 06, 2009

The tests have been carried out in accordance with the instructions of the client.

The test results are presented in the records of tests with the performance of the tested apparatus and the observations made during the tests. The oscillograms are attached hereto.

The test results apply only to the tested specific samples.

This document shall not be reproduced except in full, without a written approval of KERI.

This report shall not be used for any purpose such as PR brochures, propaganda, advertisement and/or legal proceedings, unless for the granted purpose.

No. OF PAGES records (3), photographs (1), circuit diagrams (0), oscillograms (4),
INCORPORATED drawings & descriptions (0), attachments (0)



Prepared by


Kim, Young-Sung

Verified by


Jung, Jin-Sam

Approved by
(Technical manager)


Park, Sung-Kyun

Power Apparatus Testing & Evaluation Division

KERI

KOREA ELECTROTECHNOLOGY RESEARCH INSTITUTE

Sa 1-dong 1271-19, Sangnok-gu, Ansan-si, Gyeonggi-do, Korea, 426-170

Tel : +82-31-8040-4114, Fax : +82-31-8040-4499, www.keri.re.kr

KERI Laboratories are accredited by KOLAS (Korea Laboratory Accreditation Scheme)

DF-CA-21/11/01

Table of contents

Items	Sheet No.
Table of contents	2/3
Ratings of the test object assigned by manufacturer and proved by tests	2/3
List of tests	2/3
Test results	3/3
Photographs	-

Tested by :

KERI

Kim, Young Sung

Witnessed by :

Photograph :

Photo. IT01 Specimen and measurement of limiting voltage

Ratings : given by test applicant

Surge Protective Device

Applied standard

Applicant's specifications

Manufacturer

Ground Co., Ltd.

Designation

LP-34-38-40M

Rated voltage

AC 400Y/230 V

List of Tests :

Description of tests	Standard and clause	Sheet No.
1 Limiting voltage test	-	3/3
2 Review of test results	-	3/3

1 Limiting voltage test

Test method and requirement	Applied point		Polarity	Result kV	
				1	2
<ul style="list-style-type: none"> o Test specification - Open-circuit voltage of the generator U_{oc}: 6 kV, (1.2×50) μs - Short-circuit current of the generator : 3 kA, (8×20) μs - Effective output impedance of the generator Z_f : 2 Ω - Repeat : twice for each polarity o Requirement - Measuring the limiting voltages on protected line terminals 	Line-Neutral	L1-N	Positive	0.88	0.88
			Negative	0.93	0.88
		L2-N	Positive	0.88	0.95
			Negative	0.91	0.91
		L3-N	Positive	1.02	0.99
			Negative	0.93	0.93
	Line-Ground	L1-G	Positive	1.35	1.39
			Negative	1.46	1.33
		L2-G	Positive	1.57	1.46
			Negative	1.61	1.24
		L3-G	Positive	1.41	1.66
			Negative	1.59	1.66
	Neutral -Ground	N-G	Positive	1.46	1.28
			Negative	1.44	1.48
	Line-Line	L1-L2	Positive	1.52	1.52
			Negative	1.57	1.55
		L1-L3	Positive	1.57	1.57
			Negative	1.59	1.57
		L2-L3	Positive	1.59	1.59
			Negative	1.59	1.57

※ See Osc. IT01-04

2 Review of test results

2.1 This test report is the results carried out in accordance with applicant's specifications for the specimen submitted by test applicant End.

Photographs



Specimen



Measurement of limiting voltage

Measurement of limiting voltage with combination wave







